CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0028:224 Page 1 of 3

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Notifier. One Fire-Lite Place. Northford CT 06472-1653

Contact: Larry Flood (203) 484-1200 FAX (203) 484-7309

DESIGN: Model NFS-3030, NFS-3030E, NFS2-3030, NFS2-3030E fire alarm control units. Local,

auxiliary, remote station (PPU), proprietary (PPU), central station (PPU), automatic, manual, waterflow and sprinkler supervisory services. *Suitable for use as a releasing service. Refer

to listee's data sheet for detailed product description and operational considerations.

System components:

ACM-8R/-16AT/-24AT/-32A/-48A Annunciator Control Modules

ACPS-2406 Addressable/Charger Power Supply AEM-16AT/-24AT/-32A/-48A Annunciator Expander Modules

AFM-16A/-16AT/-32A Annunciator Fixed Modules
AKS-1B Annunciator Key Switch

AMPS-24 Addressable Main Power Supply
APS-6R Auxiliary Power Supply

ARM-4 Auxiliary Relay Module

BB-100/-200 Battery Box
BMP-1 Blank Module

BGRA-SCS, BGRB-SCS, Smoke Control Enclosures for SCS Modules CEF-SCS, RSA-SCS, RSB-SCS, Smoke Control Enclosures for SCS Modules Smoke Control Enclosures for SCS Modules Smoke Control Enclosures for SCS Modules

BP-4 Battery Panel BP2-4 Dress Panel

BX-501 Intelligent Detector/Sensor Base

B-501 Intelligent Base

B-710LP Intelligent Detector Base

CAB-4 Series Enclosure
CHG-120 Battery Charger

CHS-4L/-4MB/-4N/-6/-M3/-PS/*-BH1 Chassis CPU2-3030D**/***CPU2-3030ND CPU Board

CRE-4 Control Relay Expander
CRM-4RK Control Relay Module
CRT-2 Display Terminal
DCM-4RK Dual Channel Module

DP-1B Blank Panel

DP-DISP Display Dress Panel DPDW-1B, DPSW-1B, XPDP, Dress Panels

VP-2B Dress Panel

Dress Panel

DPI-232 Direct Panel Interface
FCPS-24 Field Charger/Power Supply
ICE-4 Indicating Control Expander
ICM-4RK Indicating Circuit Module

Recert. 04-13-2006 jw *Rev. 03-25-2008 mt

Listing No. 7165-0028:224 Page 2 of 3

IZE-A Initiating Zone Expander IZM-8RK Initiating Zone Module ISO-X Isolator Module

LCD-80 Liquid Crystal Display Module
LCM-320/LEM-320 Loop Expander Module
LDM-32/-E32/-R32 Lamp Driver Modules

MP-1B Blank Panel

MPS-24B Power Supply Module

NBG-12 Series

NCA-2

NCM-W/-F

N-ELR

Addressable Manual Pull Station

Network Control Annunciator

Network Control Module

End of Line Resistors

NFS-LBB/-LBBR/-BB-25/-BB-17 Battery Box PRN-6 Printer

R-120/-2.2K/-27K/-470/-47K

RA-400/-400Z

RKS-S

Remote Annunciators

Remote Security Keyswitch

RPJ-1

Remote Paging Jack

RPT-W/-F/-485W/-485WF Repeater

RM-1/-1SA Remote Microphone SCS-8 Smoke Control Station

SCS-8L Smoke Control Lamp Driver Station

SCE-8 Smoke Control Expander
SCE-8L Smoke Control Expander Lamp

STS-1 Security Tamper Switch TM-4 Transmitter Module

TR-A4/-B4/-C4/-D4
UDACT
UZC-256
UCE-4
VCM-4RK
VS4095
Trim Ring
Universal DACT
Universal Zone Coder
Voice Control Expander
Voice Control Module
Keltron Remote Printer

XP5-C/-M Transponder

XPC-8 Transponder Control Module

XPIQ Transponder Quad Intelligent Audio Module

XPM-8/-8L Transponder Monitor Modules
XPP-1 Transponder Processor
XPR-8 Transponder Relay Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

Listing No. 7165-0028:224 Page 3 of 3

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and

indicating devices. This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition. Refer to listee's Installation Instructions

Manual for details.

This control unit meets the requirements of UL-864, 9th Edition Standard.

NOTE: For *Fire Alarm Verification* feature (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

Recert. 04-13-2006 jw *Rev. 03-25-2008 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 12, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division